

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 71.....

Dated: 03/02/25

It is certified that an inspection team headed by Shiv Shankar Prasad (Chemist) from PHED Supaul inspected the KOSHI PUBLIC SCHOOL- Vishal Nagar, Tharbitia, Shivpuri (Maladh), Kishanpur, Supaul - Bihar 852138 on 31.01.2025 and found that the KOSHI PUBLIC SCHOOL has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State U.T Govt.

The above is valid for a period of 01 Year.

Signature with Seal:.....

Name:.....

Designation:.....

Name & Address of Department:.....

To,

KOSHI PUBLIC SCHOOL,

Vishal Nagar, Tharbitia, Shivpuri (Maladh),

Kishanpur, Supaul - Bihar 852138

  
Principal  
Koshi Public School  
Vishal Nagar Tharbitia  
Shivpuri Maladh  
Kishanpur, Supaul

  
Manager  
Koshi Public School  
Vishal Nagar, Tharbitia  
Shivpuri, Maladh (Supaul)



# PUBLIC HEALTH ENGINEERING DEPARTMENT

P. H. Division, Supaul

## WATER QUALITY RESTING REPORT

Location of Source :-Koshi Public School Vishal Nagar, Tharbitia

Date of Sampling :- 31/01/2025

Date of Testing :- 03/02/2025

Sl. No.	PARTICULARS	PERMISSIBLE LIMIT	Obsrvation	Remarks
1	pH	6.5-8.5	7.09	
2	Turbidity	1-5 NTU	<1	
3	Conductivity		182	
4	TDS	500-2000 mg/L	110	
5	Total Hardness	300-600 mg/L	67.07	
6	Iron	1.0 - NR mg/L	0.45	

Note:- NR= No Relaxation

*SPV*  
03/02/25  
Research Assistant (Chemist)  
DLWTL, Supaul

*SPV*  
03.02.25  
Assistant Engineer  
P.H. Sub Division, Supaul

*B. M. S.*  
Principal  
Koshi Public School  
Vishal Nagar Tharbitia  
Shivpuri Maladh  
Kishanpur, Supaul

*Alp*  
Manager  
Koshi Public School  
Vishal Nagar, Tharbitia  
Shivpuri, Maladh (Supaul)